

A Novel Artificial Neural Network Topology to Enhance Combined Cycle Power Plants Modeling Capabilities

Efstratios L. Ntantis¹ and Vasileios Xezonakis^{1,2}

¹Aerospace Engineering Department, Amity University Dubai, Dubai, UAE

²Mechanical Engineering Department, University of South Africa, Pretoria, South Africa

(Received 28 November 2024; Revised 05 June 2025; Accepted 01 July 2025; Published online 30 July 2025)

Abstract: Neural networks are prominent among concurrent advanced technology techniques due to their capacity to deal with massive long-term datasets and the nonlinear modeling in combined cycle power plants. This paper studies an adaptation of the Levenberg–Marquardt training algorithm to train and assess a combined cycle power plant output. The most robust electric power predictions are identified for 70% of the training data, 15% of the validation, and 15% of the testing data. The sensitivity impact of reducing the design variables to two and three via a modern methodology for the electric power estimation at a reduced cost constraint is presented. The adapted actual experimental data (9568) from six years of four input parameters, ambient temperature, exhaust vacuum, ambient pressure, and relative humidity, were used. These input parameters were combined in different datasets as the ambient temperature (P1), the exhaust vacuum (P2), and the ambient pressure (P3), applied to different settings using (P1+P2, P1+P3, P2+P3) for the two input variables and (P1+P2+P3) for the three variables. The implementation of the Levenberg–Marquardt training code for a hidden layer size of (20, 500) contributes to the output power prediction. The regression values obtained for the two variables combined datasets (P1+P2, P1+P3, and P2+P3) were 0.9701, 0.9658, and 0.9401, thus highlighting the superiority of the (P1+P2) dataset. When the design variables were increased to three (P1+P2+P3), a better prediction of electric power in terms of the improved regression value 0.971 was observed with a mean square error of 13.8389. These mean square error and regression coefficient values for both network settings (P1+P2) and (P1+P2+P3) showed improved performance compared to past studies. Hence, this new approach of neural network configuration with the three input parameters provides a novel prediction of the output power, which can be used to validate the combined cycle power plants and has computational benefits in other real-world applications.

Keywords: artificial neural network; combined cycle plant; Levenberg–Marquardt; regression analysis; thermal plants power

I. INTRODUCTION

The primary objective of every country's economic development is the production and use of diverse forms of energy, including heat, chemicals, and electricity. In this respect, electricity is the main source type in the region of interest. Traditional and hybrid power plants implement an assortment of fossil fuels and energy sources for the production of electricity. Electricity generation employing power plants employs a variety of renewable energy resources, such as hydroelectric, solar, and wind. The variety of traditional thermal power plant stations has recently declined for several reasons, including increasing capital costs, installation challenges, and resource availability. Consequently, active plants currently produce 65% of the world's energy despite negatively influencing the environment [1].

Combined cycles are composed of two different thermal cycles capable of achieving the highest inlet temperature of the gas turbine (GT) and the lowest temperature of the outlet gases, contributing to the plant's loss reduction. Therefore, the combined cycle power plants (CCPP) are superior to the conventional thermal power plants for several reasons, being one of the fastest and most effective ways to generate electricity. In particular, their performance reaches up to 60%, producing 50% more electricity from the

same fuel using the simple thermal power plant. CCPP's popularity is also highlighted due to its quicker start-up capabilities and minimum environmental impact [2,3]. Among other benefits of CCPP, compared to other fossil fuel technologies, are the smaller investments per kW, the faster construction, and the higher operation flexibility [4]. Their main drawback is the increased production cost, but their reputation renders their adaptation in the present study necessary [2,3,5]. The current study's methodology and materials section provides the functional attributes of CCPP.

The optimum profit from the power production in megawatt-hours in the power market depends on the power plant's full load electrical power output [6]. Furthermore, a significant step toward the sustainable advances of CCPP, where the optimum energy utilization during peak requirements requires the computation of heating loads under different outdoor weather conditions [7]. Therefore, developing a method to predict power output using various combinations of input features becomes both crucial and challenging. In this respect, several studies have been conducted to accurately and efficiently predict the electrical CCPP power output, adapting different predictive models and tools. These tools include the incorporation of cutting-edge techniques such as artificial neural networks (ANN) and machine learning (ML) methodologies, with performance, reliability, and accuracy measures such as the mean square error (MSE) and the regression coefficient (R) as discussed in the present study. The scientific relevance is summarized in predicting electrical power output in a CCPP based on the

Corresponding author: Efstratios L. Ntantis (e-mail: entantis@amityuniversity.ae).

electrical power prediction with the novel reduced set of input features, computational benefits, and less complex procedures, and a novel acceptable prediction of the evaluation metrics implemented. Various thermodynamic studies, using energy–exergy analysis, have also been conducted by potential investigators, are beyond the scope, and thus are omitted. The technological evolution brought a rapid expansion of various *computerized evolved* techniques such as Artificial Intelligence (AI) as part of ML, dominating the energy sector, improving the respective CCPP's performance with distinguished characteristics. ANN was initiated in the mid-20th century to model the human brain through computer systems, which had limited use due to limited computational power. Recently, the neural network's ability to handle many parametric data at the lowest computational cost has been highlighted. Therefore, adapting ANN's topology in many real-world applications brought a rapid expansion in the energy sector, addressing the nonlinear interconnection between the input thermodynamic parameters and the output parameters, such as the electric output power (EP) and the performance of a power plant's model. These topological characteristics will be briefly mentioned below.

II. TOPOLOGY OF THE ANNs

ANNs are ML models inspired by biological neural networks, depending on a variable number of inputs, composed of interconnected neurons that receive input information, perform progressively complex calculations, and then use the output information for solving problems. Their framework is dependent on the network's arrangement, along with the nodes, and is classified as single-layer and multi-layer perceptron (MLP) networks [6].

In single-layer networks, there is an interaction of the input layer (nodes) with different weights separated by the hidden layer, before the final sending of the information at the output layer, and a sample illustration of such a network with three inputs, separated with three hidden layers and two outputs is illustrated in Fig. 1.

In the present paper, the MLP feed-forward back propagation neural networks (FFBP) configuration of the ANN, as illustrated in Fig. 2, consists of a number of interconnected adaptive units (neurons), processed in parallel. Backpropagation neural network (BPNN) is a linear regression algorithm related to supervised learning, and it is a gradient descent technique adjusting the weights, minimizing the loss function via various activation functions, and improving the output's metric (Electric Power, EP)




Fig. 1. Topology of a single-layer network with input, hidden, and output nodes.




Fig. 2. MLP configuration of a BPNN with input, hidden layers, and an output layer.

accuracy. Hence, commonly used activation functions include the log-sigmoid (*logsig*) and the tan-sigmoidal (*tansig*), whereas for a more accurate forecasting of the EP, the superiority of *tansig* is designated. The input parameters considered are as follows: ambient pressure (AP), exhaust volume, ambient temperature (AT), and relative humidity (RH), while the EP represents the output variable of the CCPP power plant.

The training process of the BPNN consists of a four-step procedure designed to improve the model's performance iteratively. It begins with allocating initial weights, where the network's weights and biases are randomly assigned to initiate the learning process. This is followed by adopting the feed-forward operation using gradient descent, where input data flow through the network, and gradient descent helps determine how the weights should be adjusted. The third step involves error propagation by implementing a loss function, which calculates the discrepancy between the predicted and actual outputs to evaluate model performance. Finally, the process concludes with updating weights and biases, using the computed errors to refine the model's parameters and enhance its predictive accuracy.

Hence, small weight values are assigned in the feed-forward stage, forecasting the output design parameter. The respective error (loss function) runs back at the ANN, whereas the biases and the weights are adjusted, and the entire process continues till the weights are assigned at the loss error's minimum value. The respective layers, illustrated in Fig. 2, are denoted as i the input layer, j the hidden layers, and k the output layer. The input training vector is expressed as A , whereas $A = [a_1, a_2, \dots, a_n]$, and the desired value vector is denoted with B , where $B = [b_1, b_2, \dots, b_n]$. The input layers i and the hidden layers j are linked via the weight R_{ij} and considering the output layer k , the respective hidden and the output layers are connected via S_{jk} . Hence, the network is initiated using a small random signal a_1 , received by the input unit, and then it is transmitted to all the hidden layer units. Therefore, the sum p_{ij} is calculated via:

$$p_{ij} = \sum R_{ij}a_1 + c \quad (1)$$

whereas $c = [c_1, c_2, \dots, c_n]$ is the bias design vector. In case the activation function (*logsig*) of a neuron is 1, their weights are defined as biases, and the *logsig* is expressed as [8]:

$$f(p) = \frac{1}{1 + e^{-p}} \quad (2)$$

Hence, the signal received from the activation function is redirected to the output layer, calculated from the equation below.

$$z_j = f(p_{ij}) \quad (3)$$

As illustrated in the following expressions, this final signal is multiplied by the cap S sub j k.

$$p_{jk} = \sum S_{jk} z_j + c \quad (4)$$

$$p_k = f(p_{ijk}). \quad (5)$$

In case that all the output units in the output layer have received a signal from the hidden layers, the output unit error generated becomes:

$$\delta_k = (b_k - p_k)f(p_{ijk}) \quad (6)$$

whereas δ_k is the output unit error.

The output unit error travels back via the hidden layers, where an identical error is calculated, and based on the results, the adjustments to these biases and the weights are given as:

$$S_{jk}(new) = S_{jk}(old) + \Delta S_{jk} \quad (7)$$

where ΔS_{jk} is the difference deduced when the error was fed back into the architecture through hidden layers:

$$\Delta S_{jk} = a\delta_k z_j \quad (8)$$

where a is the learning rate, for $0 < a < 1$.

Therefore, the respective error between the predicted and the actual data is expressed using the MSE metric of the network's performance as:

$$MSE = \frac{1}{n} \sum_{i=1}^n (target - output)^2 \quad (9)$$

Incorporating neural networks led researchers to predict the CCPP performance under various maximum and operational base loads, such as deploying the transparent open box to predict output EP [9]. In the GTs field, the performance of a high-dimensional model representation coupled with an ANN is reliable [10]. The evaluation of a micro-GT's performance under different weather conditions is presented [11]. Furthermore, a combined cooling, heating, and power plant for performance prediction [12] was used to validate the condition monitoring and diagnosis methodology of a combined heating and power plant [13]. The performance of an industrial GT, considering the RH, AP, and AT as input variables, with encouraging results after 10,000 epochs, is examined [14]. The regression method is used to model the baseline consumption of a combined heat and power plant and the EP prediction of a CCPP [15,16].

In power plants with multiple objectives, for the estimation of the output power of a coal-fired power plant as well as the thermal efficiency and the environmental effect [17–21], the modeling and optimization of a combined gas and steam (COGAS) power plant implementing a MLP model contribute to maximum efficiency [22]. The assumed heat rate of a COGAS power plant is an output parameter using three input parameters: the fuel gas heat rate (P1), the CO₂ percentage (P2), and the power output (P3); this combination and redundancy achieved reliable outcomes [23].

This research shows how the power and performance of a CCPP increase by reducing the input design variables. The practicals started with 4 variables, slightly reduced them to 3, and then to 2. The study shows that using ANNs is the most efficient method for addressing the energy sector problem. A more detailed literature review evaluation of the AI approach and various ML techniques

within the power sector with positive qualities is depicted in the following section.

III. LITERATURE REVIEW

ANNs are an efficient tool for the consideration of complex problems and have been adapted by several investigators worldwide for several real-world engineering problems in the solar [24] and in the solar power sector in islands [25]. In the power plant sector, various techniques for a number of input and output datasets have been proposed over the last few years, with robust outcomes. Therefore, for various thermodynamic input parameters, the power output forecasting of a CCPP is also forecasted [26]. The validity and reliability of the neural networks in a traditional GT power plant are studied by the AT impact on power generation and fuel consumption [27]. An interesting analysis of the single-shaft GT provided encouraging outcomes [28]. The control and performance analysis of a combined heat and power plant is studied [29]. The monitoring of the drum level of a traditional thermal power plant, adopting a BPNN method, was presented [30]. In the GT field, the prediction of the compressor's performance map with the noise reduction of the measured data via neural networks, towards improving their operational quality, is studied [31]. In a steel thermal plant with implicated input variables, the advocacy of ANN efficiency over the autoregressive moving average exogenous time series model is underlined [32]. The overall attainment evaluation in a Western Balkan power plant under controlled modifications is proposed [33].

An interesting comparison between the MLP and the radial basis functions (RBF) networks for the fault analysis of the GTs is conducted, highlighting the superiority of RBF [34]. Furthermore, the implementation of neural networks to reduce unusual (indirect) losses in a thermal power plant is presented [35]. The short-term load forecasting in various types of power plants is depicted. Therefore, a hybrid model consisting of a fuzzy logic exergy model and a CCPP neural network contributed to robust solutions [36]. A hybrid model integrating a neural network with a genetic algorithm, selecting the optimum architecture via the trial-and-error process, improved the computational cost [37]. Adaptation of various deep learning methods, such as the single and fast neural networks, is also investigated for the EP estimation of a CCPP, with secured robustness [38]. A statistical inference prediction of the performance model with reliable outcomes and improved computational cost in the process is highlighted [39]. Various ML techniques for the monitoring process of a CCPP are also incorporated [40]. A multilinear regression ML methodology for an optimum predictive load estimator is achieved [41]. A decision-making tool of coherent complex data environmental control forecasting, utilizing AI, is validated [42].

A sensitivity analysis of the interpreted neural networks, jointly with various agnostic models, contributes to inspirational and productive results under full operating conditions [43]. In the combined cycle GT field, deep learning methodologies investigated the control optimization of its auxiliary components [44]. A comprehensive review of achieving efficient optimum solutions in various CCGT plants, incorporating an Adaptive Inference Neuro-Fuzzy logic system, is envisaged [45]. A novel ANN was employed for power output forecasting using an electrostatic discharge optimization technique [46]. A brief introduction of the gap's closure contribution to knowledge, as well as the objectives of the present study, is envisaged in the following section.

Table I. Concise overview of ANN techniques for boosting-related CCPP in literature

	Types of plants	Plants' choice constraints	Types of ANN techniques	Responses	Remarks and issues on undersupplied	Findings	References
1	CCPP	Ambient Temperature, Exhaust Vacuum, Ambient Pressure, Relative Humidity	Machine Learning Methods (MLAs)	CCPP hourly electric power prediction	Various MLAs, such as the k th-nearest neighbors (KNN), gradient-boosted regression rate (GBRT), Linear Regression (LR), ANN, and Deep Neural Networks (DNN), estimate the electric power output with significant outcomes, accurately.	Results show that the state-of-the-art surpasses GBRT in terms of predicting optimum electric output power (EP)	Siddiqui <i>et al.</i> [49].
2	CCPP	Ambient temperature, Exhaust Vacuum, Ambient pressure, Relative humidity	Hybrid Machine Learning approaches	Power plant's output power with the minimum waste	BOA combined with a PPE algorithm, BOAPPE, jointly with the SVM forecasted the output power of CCPP with robust solutions, avoiding technical issues on the power outage	BOAPPE methodology improved the convergence speed, avoiding the trapping into local optimum solutions	Wang <i>et al.</i> , [50]
3	Combined Cycle Gas Turbine Power Plant	Inlet temperature (flue), absorber column operating pressure, amount of exhaust recycled, and amine concentration	Taguchi Design of Experiment	Optimization of post-combustion CO ₂ capture	Monoethanolamine solvent, employed through the Taguchi design experimental method, mitigated the energy requirements of the system, studying the varying inlet flue gas temperature, the absorber column operating pressure, the exhaust gas recycle, and the amine concentration under statistical investigation.	The statistical optimization concept of the post-combustion capturing of CO ₂ is demonstrated.	Petrovic and Soltani [51]
4	Natural gas-fired combined cycle power plant	Flue gas emissions dataset between 2011 and 2015	Hybrid Machine Learning method	Power plant's NO _x emissions prediction	ANFISGA strategy evaluated accurately the NO _x emissions at the minimum error, with a positive impact on the CCPP performance, resolving the environmental and the society's needs	The impact of the coupled GA with ANFIS provided optimum solutions	Dirik [52]
5	Gas Turbines Combined Cycle Power Plant	Dynamic optimal set point for the regularization level	Hybrid Machine Learning technique	Power plant's efficiency forecasting	An integrated Fuzzy Logic model with a Genetic Algorithm (GA) predictive supervisory controller accurately evaluated the power plant's performance, reducing the plant's non-linear effects.	The coupled fuzzy (GA) logic controller optimizes GTCCPP performance solutions.	Saez, Mila, and Vargas [53]
6	CCPP boiler	Input data are selected by means of a sensitivity analysis	Machine Learning approaches (MLAs)	CCPP boiler performance	A cluster of optimum Taguchi-Sugeno Fuzzy Logic models (FL) successfully derived the CCPP's efficiency and the tackling via a Chen series sensitivity method of the nonlinearities associated with the boiler's operation.	The economic optimization of the plant in terms of the nonlinear FL model and the superheated steam pressure via the linear FL model	Seaz and Zuniga [54]

(continued)

Table I. (continued)

	Types of plants	Plants' choice constraints	Types of ANN techniques	Responses	Remarks and issues on undersupplied	Findings	References
7	CCPP	Ambient Temperature, Exhaust Vacuum, Ambient Pressure, Relative Humidity	Hybrid ML Technique	CCPP hourly output power estimation	An integrated MLP topology of a neural network (ANN) model with a Genetic Algorithm (GA), towards the accurate electric power output estimation, increasing the regression R values of the network (reliability and robustness), compared to identical studies.	Results for the optimum MLP architecture show that the root mean square error (RMSE) reaches a value of 4.304, substantially lower than the available MLPs in the literature, but higher than several complex algorithms, such as the KStar and the Tree-based algorithms.	Lorencin, Mrzljak, and Car [55]
8	CCPP	Ambient Temperature, Vacuum Exhaust, Ambient Pressure, Relative Humidity	Machine Learning Approaches (MLAs)	CCPP output power full load forecasting and anomaly detection.	Full load estimation of the power output using several machine learning algorithms, such as Linear Regression (LR), Support Vector Machines (SVM), Random Forests (RF), and neural networks (ANN), contributing to the reduction of the anomalies and the operation's detection of a CCPP power plant	Results show that the superiority of the Random Forest (RF) technique by means of the highest accuracy $R^2 = 0.96$, using less than half of the 10,000 dataset points, while the unsupervised algorithms identified sparse synthetic anomalies of 1.5 % from the entire dataset	Hundi, Shahsavari [56]
9	CCPP	Ambient Temperature, Vacuum Exhaust, Ambient Pressure, Relative Humidity	A stacking prediction method, based on a multi-model ensemble, and a traditional machine learning method, such as the Random Forest (RF)	An efficient and reliable CCPP power output under full conditions prediction model	Full load evaluation of the power output from a CCPP plant, implementing a stacking ensemble optimization algorithm, compared with the conventional Machine Learning algorithm (RF) and other ensemble methods cited in the literature to address the accurate planning of the electricity generation and utilization	The results demonstrate a high prediction robustness of the power output, under multiple complex environmental variables, designating its superiority, in terms of various machine learning methods such as the Random Forest (RF) and additional ensemble methods	Qu <i>et al.</i> [57]
10	NGCCP	Effective use of underground resources such as natural gas	Life performance models such as FL and ANN	Power output estimation was carried out	Full loading conditions power output prediction comparing FL and ANN models, addressing the life performance forecasting via underground resources such as natural gas.	Results depict that the relative error estimation via FL varies between 0.59 % – 3.54 % and via ANN varies between 0.001 % – 0.84 %, illustrating the neural networks' advocacy	Karacon <i>et al.</i> [58]

IV. GAPS IN KNOWLEDGE, MOTIVATION, AND OBJECTIVES

In the present study, the primary interest is dedicated to CCPP plants, with the main target to model and to forecast their performance in terms of an MLP FFBP neural network for a multidimensional dataset (9568) under full loading conditions in Turkey [47]. These four parameters include the AT, exhaust volume (V), AP, and RH, to predict the EP, contributing to the upgrading of the computational performance of the CCPPs. Recently, there has not been enough contribution about the impact on the performance computation and the robustness by deducing various input

parameters in the literature. This gap is filled by introducing a novel methodology of reducing the specific input design variables into 3 (AT, V, and AP) and 2 different combinations (AT and V, AT and AP, V and AP). Consideration of the RH, in the reduced input parameters due to meaningless outcomes, is omitted, and a comparison with identical studies will be pointed out. Another key contribution of this pioneering study is to deliver reliable and accurate deliverables regarding the network's performance, forecasting the EP. Despite the reduction, this study ensures accuracy in predicting the attitude of CCPP modeling. This streamlining improves computational efficiency and uniquely contributes to the overall research.

Table I highlights the implementation of AI and ML techniques in traditional and hybrid combined power plants. Recently, many tools have been adopted to model and forecast the EP of CCPP plants. There is inadequate research on the selection and appropriate request of the cutting-edge tools, namely AI-based extrapolative models that can simulate nonlinear patterns in the CCPP. Hence, the entire trend is based on the premise that this investigation applied an MLP network structure of the reduced input features (3 and 2) of the neural network (FFBP) that is more robust and reliable on the existing dataset (9568), using novel findings and making a comparison with previous studies [16,23,29]. Furthermore, to the best of the authors' knowledge, MLP network techniques have not been fully utilized in previous power plant modeling studies. This new approach addresses the multidimensional handling of the novel reduced dataset to prevent power failure and stabilize its operation. The methodology used in the present study will be highlighted in the following section.

V. METHODOLOGY

ANN can handle complex information, moving towards understanding the choice from the CCPPs [3]. Therefore, the primary objective is to leverage ANNs to forecast plant performance in terms of EP. The CCPP comprises a GT, a steam turbine, and a




Fig. 3. Functional diagram of a CCPP power plant.

heat recovery steam generator, as illustrated in Fig. 3. In a CCPP, a GT produces hot gases and outputs EP. These gases from the GT pass over a water-cooled heat exchanger, generating steam, which is used to produce output power (EP) with the aid of the steam turbine coupled with generators. An extended description of a CCPP's operation can be found in [5,6]. In addition, the feature to evaluate the multiple input contrast and hidden layer functions allows a detailed analysis of the interdependencies among the input features, using the AT, exhaust vacuum, AP, and RH on the power output. Therefore, the neural networks handle the regression tasks with ease. Furthermore, it justifies its selection for achieving efficient and timely predictions in this research study. The MATLAB neural network toolbox (*nntool*) facilitates the exhaustive simulation part to be compared with reliable online datasets [47]. The main metrics to be explained are the test and the performance of the entire dataset, followed by a brief description below.

A. DATASET PREPARATION

The CCPP dataset consists of 9568 non-stationary points received from a gas-fired power plant with a 420 MW capacity in Turkey for 6 years from 2006 to 2011 [47]. The respective input features involved in this procedure are the AT, exhaust vacuum (V), AP, and RH, while the output forecasted variable is the EP. This primary dataset comprised 674 datasets in .xls format for a daily representation, although a few noisy and incompatible datasets were included. After some preprocessing steps, these conflicting and noisy points were rejected due to the disturbance interference. The primary aim of this study is to make a deep comparison of the various datasets' network performances. Thus, the following section presents an overview of the dataset, depicting a sample of the input and the output parameters to be considered, as Table II illustrates. Therefore, the novel capabilities of reducing the input parameters into 3 (AT, V, AP) and the different combinations into 2 (AT and V, AT and AP, V, and AP), as explained in section II, contribute to this direction [47]. The primary goal of the testing is to evaluate the reduced dataset, which includes both input and output features. According to the MATLAB Neural Network Toolbox (*nntool*) [48], the dataset is by default divided into 75% for training, 15% for testing, and 15% for validation. This partitioning is done while considering the limited CPU resources, as shown in Fig. 4. In this study, despite the massive amount of data, there is no reduction in the training, testing, and validation subsets, and the setting of the entire procedure before the simulation is examined later.

Table II. Actual data were taken from a CCPP [47]

Sample	AT (Input) (°C)	V (Input) (cmHg)	AP (Input) (mbar)	RH (input)	EP (output) (MW)
1	9.34	40.77	1010.94	90.01	490.48
2	23.64	59.49	1011.4	74.2	445.75
3	29.74	56.9	1007.15	41.91	439.76
4	19.07	49.69	1007.22	76.79	452.09
5	11.8	40.66	1017.12	97.2	464.43
....					
9565	16.65	49.69	1014.01	91	460.03
9566	13.19	39.18	1023.67	66.78	469.62
9567	31.32	74.33	1012.92	36.48	429.57
9568	24.48	69.45	1013.86	62.39	435.74




Fig. 4. Percentage sampling of the CCPP entire dataset (9568) in training, testing, and validating.

Table III. Input and output variables of the ANN model

Term notation	Variable description	Output power
Two	P1+P2	AT (°C) and V (cmHg) EP
	P1+P3	AT (°C) and AP (mbar) EP
	P2+P3	V (cmHg) and AP (mbar) EP
Three	P1+P2+P3	AT (°C), V (cmHg), and AP (mbar) EP

B. THE SETTING OF THE NETWORKS

A FFBP is implemented in the MLP structure of the present neural network, implementing a Levenberg–Marquardt (LM) training algorithm, considering the MSE as the performance metric. The theoretical background of LM is beyond the scope; thus, it is omitted. The learning function has changed the weight between the neurons by implementing the FFBP algorithm [21]. Furthermore, the adopted activation function in this study is the *tansig* for robustness reasons. The input and output parameters for the reduced number of parameters (2, 3) are illustrated in Table III. An architectural sample network model of two input parameter combinations (I, P1+P2) identical for the (P1+P3, P2+P3) with two hidden layers (H) of two and one neuron, including an output parameter (EP), is illustrated in Fig. 5.

Figure 6 designates the combined model with the three input variables (P1+P2+P3) with two hidden layers (H) of three and one neurons (nodes), as well as an output parameter (EP), whereas the output parameter corresponds to the output EP.




Fig. 5. ANN structure model for two input parameters (P1+P2).




Fig. 6. ANN structure model for three input parameters (P1+P2+P3).

C. FLOWCHART OF THE PROPOSED ARCHITECTURAL MODEL

The proposed training, testing, and validation process for the LM training algorithm of the reduced input features into the combined 2 and 3 of the current test case with 10,000 epochs and 1000 validation steps is presented in Fig. 7. Therefore, the loop with respect to the two and the three input parameters is currently assumed.

The network is constructed using the neural network's architecture, including the neurons, layers, training function (LM), and the learning algorithm (*tansig*). The neural network architecture for the present study is configured automatically with MATLAB software's graphical user interface capabilities [48]. Further investigation to amend the dataset percentage regarding the training/testing/validation principle is not considered for novelty reasons. The sensitivity and reliability of the outcomes after reducing the input parameters from four have been investigated [6]. Additionally, the combination of two input features has also been explored in studies [16,23,29], yielding interesting and reliable results, as explained below.

VI. RESULTS AND DISCUSSION

The analysis of the results with a few concluding remarks is envisaged in this section, forecasting the output power of a fully operational CCPP plant, through the reduced number of combinations of two input parameters (P1+P2, P2+P3, P1+P3) and of three input parameters (P1+P2+P3). Each design variable from the combined input variables (P1+P2, P2+P3, P1+P3) presents a different impact on the output parameter (EP). Hence, each of the three parameters (AT, V, AP) was examined for the respective data size (9568) (70% training, 15% validation, 15% testing) for 20 hidden layers. These settings for the respective number of simulations are depicted in Table IV. The training algorithm LM was adopted for the whole procedure, and its theoretical background is beyond the scope, thus excluded, and more information can be found in the literature. The respective network's testing and performance database is expressed in terms of the MSE. A sample geometry of the network of the two input combined variables (P1+P2, P2+P3, P1+P3) with 20 hidden layers as well as an output layer, is shown in Fig. 8. After the respective settings, the training




Fig. 7. Flow process of the present study.

Table IV. Settings of the design variables of the combined two parameters

Data size	9568
Applied variables	AT and V, V, and AP, AT and AT and AP
Hidden layers	20
Training Function	Levenberg–Marquardt (LM)
Number of epochs	1000

process adapting the LM of MATLAB neural networks *nn toolbox* [48], contributes to the achievement of robust outcomes for a different number of hidden layers, which are discussed below.

A. LEVENBERG-MARQUARDT ALGORITHM TRAINING WITH 2 PARAMETERS (P1+P2, P1+P3, P2+P3)

Figures 9–11 depict the failure of reaching the given number of epochs (1000) by means of the maximum validation allowance of the (LM) toolkit, of the combined parameters (P1+P2, P1+P3, P2+P3) reaching 53, 24, and 79 epochs.




Fig. 8. Sample geometry network structure with two input variables for 20 hidden layers [48].

The regression coefficient R (correlation) for the training, validating, and the testing of the combined parameters [P1+P2, P1+P3, and P2+P3] presents R regression values of 0.967, 0.966, and 0.965 shown in Figures 12–14, with almost excellent fitting ($R=1$) between the target and the actual dataset towards robustness as well as very good quality of the networks. The advocacy of the (P1+P2) configuration with computational benefits is also presented.




Fig. 9. Training outcome of the two input parameters (P1+P2) [48].

Tables V–VII illustrate an impact on the network's quality and performance for a different number of neurons (hidden layers), using the two combinational (P1+P2, P1+P3, P2+P3) design variables with reliable results. The same argument of the best-performing network for (P1+P2 and P1+P3) employing the MSE is depicted for 500 hidden layers, while the worst network is designated for 100 hidden layers. A different outcome exists for the final (P2+P3) combination since the maximum and the minimum performance metrics occur for neuron sizes 10 and 500. Table VIII illustrates the superiority of the (P1+P2) network with respect to the lowest (improved) MSE metrics. The network's accuracy and performance results considering incorporating a third parameter (P1+P2+P3) are shown below.

B. RESULTS WITH THREE INPUT VARIABLES (P1+P2+P3)

The addition of another variable (datasets AP, P3) to the settings of the design parameters is summarized in Table IX, and a sample network topology with 20 neurons is also illustrated in Fig. 15.

Figure 16 designates the training process setting of the LM algorithm for the (P1+P2+P3) input characteristics, whereas the neural network toolbox again fails to execute the entire number of epochs (1000), reaching 27 iterations. Figure 17 provides an estimation of the regression analysis R with a very good fitting between the actual and the target data for a value of 0.971, almost approaching an excellent value of 100%.

Table X illustrates the impact on the network's structure and precision for the different sizes of the hidden layers, highlighting that the best network performance is achieved for 200 hidden layers and the worst for 20 hidden layers. Table XI presents a comparison between the performance of the MSE values of the two design variables combined dataset (P1+P2, P1+P3, P2+P3) and the three design variables (P1+P2+P3), forecasting the supremacy of the three input parameters. The process of deducting the four design variables into the combined two (P1+P2, P1+P3, and P2+P3) and the three (P1+P2+P3) contributes to reliable outcomes comparable to identical studies of conventional CCPPs (CHP, CCPP) [16,23,29]. This exciting agreement illustrates the superiority of




Fig. 10. Training outcomes of the two input parameters (P1+P3) [48].




Fig. 11. Training outcomes of the two input parameters (P2+P3) [48].

using the (P1+P2+P3) setting in terms of the regression coefficient values (R), since it reaches a higher value of 0.9710, compared to the two combined design variables (P1+P2, P1+P3, P2+P3). Therefore, the proposed technique is more accurate and validated.

The combination of the two input parameters dataset (P1+P2, P1+P3, P2+P3) provides accurate and reliable solutions and the best prediction of the EP, identifying the superiority of the first dataset (P1+P2) in terms of the regression analysis R outcomes and the electric energy prediction (EP). None of these datasets met the requirements of satisfying the maximum number of validation checks (1000 iterations) and the performance metric regarding the MSE of validations and training process values, which again depicts the advancement of the first dataset (P1+P2). These solutions can be more accurate in encouraging and predicting the desired dataset. Moreover, these MSE and R values are slightly improved compared to other studies [16,23,29], of the best two




Fig. 12. Regression analysis outcome for (P1+P2) input parameters [48].




Fig. 13. Regression analysis outcome for (P1+P3) input parameters [48].




Fig. 14. Regression analysis outcome for (P2+P3) input parameters [48].

Table V. Neuron's impact of the (P1+P2) parameters for the LM training algorithm

Hidden layers	Training performance	Validation performance	Training regression	Validation regression	Test regression	Stopping criterion	Iteration	Best epoch
10	18.9523	20.2356	0.967221	0.96454	0.96791	"	41	25
20	16.8597	20.1873	0.967392	0.96415	0.96779	"	53	47
50	18.2058	19.3837	0.967751	0.96595	0.96784	"	64	58
100	17.3405	24.7622	0.970112	0.96775	0.96595	"	13	7
200	17.2695	18.7923	0.970056	0.96740	0.96557	"	14	8
500	15.3367	21.0806	0.970157	0.96117	0.94507	"	14	8

Table VI. Neuron's impact of the (P1+P3) parameters for the LM training algorithm

Hidden layers	Training performance	Validation performance	Training regression	Validation regression	Test regression	Stopping criterion	Iteration	Best epoch
10	23.2854	22.2311	0.958382	0.957741	0.9532210	"	30	15
20	23.1867	22.1193	0.967392	0.962874	0.9561121	"	24	18
50	23.3592	23.9369	0.960500	0.957741	0.9597410	"	64	58
100	22.1767	22.0989	0.961537	0.960790	0.9565150	"	13	7
200	21.6054	22.4459	0.961978	0.960706	0.9612210	"	14	8
500	20.6423	27.0140	0.965851	0.952698	0.9558010	"	14	8

combinational sets (P1+P2) and the three input variables (P1+P2+P3) dataset, depicting the novelty of the present study as highlighted in Table XII. Furthermore, with the redundancy of the design variables into three and two combined datasets, the multidimensional data accurately evaluates the output parameter

(EP) at the minimum computational cost, which is beneficial for future applications [21]. Therefore, the ANN validates, to the greatest extent, its application in the energy field to provide reliable outcomes in terms of improved power performance with additional benefits in this exciting sector [15].

Table VII. Neuron's impact of the (P2+P3) parameters for the LM training algorithm


Hidden layers	Training performance	Validation performance	Training regression	Validation regression	Test regression	Stopping criterion	Iteration	Best epoch
10	48.2331	47.6512	0.913200	0.911620	0.9132300	"	92	86
20	47.0158	48.7354	0.915440	0.913800	0.9208900	"	79	73
50	45.0213	49.2521	0.920610	0.911500	0.9153100	"	35	31
100	43.0685	49.4849	0.923340	0.908230	0.9129800	"	17	11
200	39.1248	45.5741	0.930450	0.913420	0.9263200	"	29	33
500	35.5872	55.2711	0.940160	0.902310	0.9711180	"	16	10

Table VIII. Lowest MSE values for the input parameters (P1+P2, P1+P3, and P2+P3)

Input parameters combinations	Mean square error
P1+P2	15.3367
P1+P3	20.6423
P2+P3	35.5872


Table IX. Settings of the design variables of the combined three parameters

Data size	9568
Applied variables	AT, V, and AP
Hidden layers	20
Training function	Levenberg–Marquardt (LM)
Number of epochs	1000

**Fig. 15.** Network geometry with three input parameters for 20 hidden layers [48].

VII. CONCLUSIONS

The EP output of a 210 MW CCPP in Turkey is modeled using regression analysis through an ANN. The approach is based on a novel methodology that reduces the original four design variables to combined input datasets, specifically, pairs (P1+P2, P1+P3, P2+P3) and the trio (P1+P2+P3), for performance evaluation. Therefore, MATLAB neural network (*nntool*) is the main adopted tool with a reliable setting and a very good impact on the network's efficiency. Interesting and reliable outcomes for different sizes of the datasets have already been produced by several investigators, and the novelty in this study is the improved MSE values for the (P1+P2) parameters as well as the (P1+P2+P3) of (15.3367, 13.8389), including their higher correlation values of (0.9701, 0.9710), compared to the respective numeric from past studies

**Fig. 16.** Training outcome of the three input parameters (P1+P2+P3) [48].

as Table XII depicts [16,23,29]. Moreover, the randomness of the reduced data is illustrated in each training procedure employing the initial weights and bias values. The impact on the network's performance of the increasing number of hidden layers for the reduced input parameters (2 and 3) test cases led to elaborating outcomes through the network's quality for a large number of neurons (500). The authentic R regression values are accomplished, showing a perfect match between the target and the actual data.

By means of the numeric, the following conclusions were arrived:

- Implementing the three different datasets (P1+P2, P1+P3, P2+P3) of the two combined input parameters predicts the EP with the following improved R regression values of 0.9701, 0.9658, and 0.9401, for the highest performance network of 500 neurons.
- The combination of the dataset using two input parameters (P1+P2) configuration predicts the output metric (EP) at an improved MSE, compared to the other two parameters (P1+P3), (P2+P3) related networks, as Table XI illustrates.
- The combination of the three input parameters (P1+P2+P3), is more reliable and robust than the two input datasets' superior (P1+P2) configuration by means of accuracy and fidelity, since the regression value R reaches 0.9710. Hence, the positive impact on its quality is enhanced.
- Adaptation of the LM training algorithm secures accurate solutions and fast simulations, a very beneficial constraint. However, the current study does not consider the other related training codes (BR and SCG).




Fig. 17. Regression analysis of (P1+P2+P3) outcomes [48].

Table X. Neuron's impact of the (P1+P2+P3) parameters for the LM training algorithm

Hidden layers	Training performance	Validation performance	Training regression	Validation regression	Test regression	Stopping criterion	Iteration	Best epoch
10	16.5213	18.0634	0.970212	0.967322	0.971224	Validation Stops	30	22
20	16.6797	19.0852	0.970173	0.967000	0.970844	"	27	21
50	15.3994	16.3332	0.970391	0.971043	0.968232	"	76	70
100	14.9842	15.9373	0.970646	0.972145	0.968832	"	18	12
200	14.3761	16.7281	0.970887	0.971041	0.972278	"	14	8
500	13.8389	17.2457	0.971012	0.971210	0.964595	"	13	7

Table XI. Comparison of the lowest MSE values of the two and the three input parameters

Input parameter combinations	Mean square error
P1+P2	15.3367
P1+P3	20.6423
P2+P3	35.5872
P1+P2+P3	13.8389

Despite the simplicity of the technique, reliable solutions are entirely provided for the forecasting of EP. In implementing a lower dataset size, there is no guarantee that the performance will not be influenced because ANN can optimize and increase the network's performance. The adopted dataset of the reduced design variables is reliable without missing any values or outliers because any duplication impacts the performance of the chosen model. According to the performance metric, this approach presents accurate performance outcomes at a lower cost. The validity of the neural networks MATLAB toolbox provides accurate and

Table XII. Comparison of the MSE and R values with previous studies [16,23,29]

Input parameters	MSE values	R values	MSE values	R values	MSE values	R values	MSE values	R values
P1+P2	15.3367	0.9701	16.3671	0.9681	16.4524	0.9652	14.5416	0.9648
P1+P2+P3	13.8389	0.9710	14.2313	0.9694	14.2613	0.9686	14.4492	0.9655

novel outcomes, replacing other modeling tools to solve identical real-world problems due to the lack of complex mathematical calculations and the privilege of providing robustness and inexpensive computations.

DECLARATION OF COMPETING INTEREST

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

CONFLICT OF INTEREST STATEMENT

There is no conflict of interest regarding the publication of this paper

REFERENCES

- [1] International Energy Agency (IEA), "Electricity, Key Findings," 2022. Available: <https://www.iea.org/fuels-and-technologies/electricity>. [Accessed: 16-Nov-2023].
- [2] S. A. Dehghani, "Combined cycle power plant with indirect dry cooling tower forecasting using artificial neural network," *Decis. Sci. Lett.*, vol. 1, pp. 131–140, 2018.
- [3] U. Kesgin and H. Heperkan, "Simulation of thermodynamic systems using soft computing techniques," *Int. J. Energy Res.*, vol. 29, pp. 581–611, 2005.
- [4] J. Kotowicz and M. Brzeczek, "Comprehensive multivariable analysis of the possibility of an increase in the electrical efficiency of a modern combined cycle power plant with and without a CO₂ capture and compression installations study," *Energy*, vol. 175, pp. 1100–1120, 2019.
- [5] General Electric, "Combined cycle power plant: how it works," 2023. Available: <https://www.ge.com/gas-power/resources/education/combined-cycle>. [Accessed: 16-Nov-2023].
- [6] P. Tüfekci, "Prediction of full load electrical power output of a base load operated combined cycle power plant using machine learning methods," *Int. J. Electr. Power Energy Syst.*, vol. 60, pp. 126–140, 2014.
- [7] H. Moayedi and A. Mosavi, "Electrical power prediction through a combination of multilayer perceptron with water cycle ant lion and satin bowerbird searching optimizers," *Sustainability*, vol. 13, no. 4, p. 2336, 2021.
- [8] A. Asghar, T. Abdul, H. Ratlamwala, K. Kamal, M. Alkahtani, E. Mohammad, and S. Mathavan, "Sustainable operations of a combined cycle power plant using artificial intelligence based power prediction," *Heliyon*, vol. 9, no. 9, p. e19562, 2023.
- [9] D. A. Wood, "Combined cycle gas turbine power output prediction and data mining with optimized data matching algorithm," *SN Appl. Sci.*, vol. 2, pp. 1–21, 2020.
- [10] Z. Liu and I. A. Karimi, "Gas turbine performance via machine learning," *Energy*, vol. 192, p. 116627, 2020.
- [11] C. Bartolini, F. Caserana, G. Comodi, L. Pelagalli, M. Renzi, and S. Vagni, "Application of artificial neural networks to micro gas turbines," *Energy Convers.*, vol. 52, pp. 781–788, 2011.
- [12] H. Taghavifar, S. Anvari, S. Khoshbakhti, S. Khalilarya, S. Jafarmadar, and H. Taghavifar, "Towards modeling of combined cooling, heating, and power system with artificial neural network for exergy destruction and exergy efficiency prognostication of tri-generation components," *Appl. Therm. Eng.*, vol. 89, no. 5, pp. 366–375, 2015.
- [13] M. Fast and T. Palme, "Application of artificial neural network to the condition monitoring and diagnosis of a combined heat and power plant," *Energy*, vol. 35, no. 2, pp. 1114–1120, 2010.
- [14] M. Fast, M. Assadi, and S. De, "Development and multi-utility of an ANN model for an industrial gas turbine," *Appl. Energy*, vol. 86, no. 1, pp. 9–17, 2009.
- [15] F. Rossi, D. Velazquez, L. Monodero, and F. Biscarri, "Artificial neural networks and physical modeling for determination of baseline consumption of CHP plants," *Expert Syst. Appl.*, vol. 41, pp. 4568–4669, 2014.
- [16] E. A. Elfaki and A. H. Hassan, "Prediction of the electrical output power of combined cycle power plant using regression ANN model," *J. Power Energy*, vol. 6, pp. 17–38, 2018.
- [17] J. Smrekar, D. Pandit, M. Fast, M. Assadi, and S. De, "Prediction of the power output of a coal-fired power plant by artificial neural network," *Neural Comput. Appl.*, vol. 19, pp. 725–740, 2009.
- [18] F. Fantozzi and U. Desideri, "Simulation of power plant transients with artificial neural networks: application to an existing combined cycle," *Proc. Inst. Mech. Eng., Part A: J. Power Energy*, vol. 19, pp. 281–292, 1998.
- [19] D. Flynn, J. Ritchie, and M. Cregan, "Data mining techniques applied to a power plant performance monitoring," *IFAC Proc. Volumes*, vol. 38, pp. 369–374, 2005.
- [20] S. Lu and B. Hogg, "Dynamic nonlinear modeling of a power plant by physical principles and neural network," *Int. J. Electr. Power Energy Syst.*, vol. 22, pp. 67–68, 2000.
- [21] L. Pan, D. Flynn, and M. Cregan, "Statistical model for power plant performance monitoring and analysis," in *Proc. 42nd Int. Univ. Power Eng. Conf.*, Brighton, UK, 2007, pp. 121–126.
- [22] V. Odokwo and K. Andem, "Modeling and efficient optimization of combined gas and steam power plant using multi-layer perceptron," *Int. J. Sci. Eng. Res.*, vol. 11, no. 3, pp. 827–835, 2020.
- [23] Y. A. Arfeniandi, W. Caesarendra, and H. Nugrafa, "Heat rate prediction of combined cycle power plant using an artificial neural network (ANN) method," *Sensors*, vol. 21, p. 1022, 2021.
- [24] S. A. Kalogirou, "Artificial neural networks in renewable energy systems applications: a review," *Renew. Sustain. Energy Rev.*, vol. 5, no. 4, pp. 373–401, 2001.
- [25] P. Lauret, E. Lorenz, and M. David, "Solar forecasting in a challenging insular context," *Atmosphere*, vol. 7, no. 2, pp. 1–17, 2016.
- [26] A. D. Samani, "Combined cycle power plant with indirect dry cooling tower forecasting using artificial neural network," *Decis. Sci. Lett.*, vol. 7, no. 2, pp. 131–142, 2018.
- [27] H. H. Erdem and S. H. Sevilgen, "Case study: effect of ambient temperature on the electricity production and fuel consumption of a simple gas turbine in Turkey," *Appl. Therm. Eng.*, vol. 26, pp. 320–326, 2006.
- [28] V. Xezonakis and E. L. Ntantis, "Modelling and energy optimization of a thermal power plant using multi-layer perceptron regression method," *WSEAS Trans. Syst. Control*, vol. 18, pp. 243–254, 2023.
- [29] M. Kaiadi, Artificial neural networks modelling for monitoring and performance analysis of a heat and power plant, M.S. thesis, Lund University, Sweden, 2006.
- [30] R. Manke and S. Tembhurne, "Application of back-propagation neural network to drum level control in thermal power plants," *Int. J. Comput. Sci. Issues*, vol. 9, no. 2, pp. 520–526, 2012.
- [31] T. Palmer, P. Waniczek, H. Honen, M. Assadi, and P. Jeschke, "Compressor map prediction by neural networks," *J. Energy Power Eng.*, vol. 6, pp. 1651–1662, 2012.
- [32] A. Rufai and H. Bashir, "Artificial neural network-based model of Ajaokuta steel power plant," *Bayero J. Eng. Technol.*, vol. 13, no. 2, pp. 125–134, 2018.

- [33] R. Mikulandric, D. Cvetinovic, G. Spiridon, and D. Loncar, "Improvement of existing coal-fired thermal plants' performance by control systems modifications," *Energy*, vol. 57, pp. 55–65, 2013.
- [34] I. Loboda, Y. Feldshteyn, and V. Pomomaryov, "Neural networks for gas turbine fault identification: multi-layer perceptron or radial basis network?" *Int. J. Turbo Jet Eng.*, vol. 29, no. 1, pp. 37–48, 2012.
- [35] S. Panda, B. Swain, and S. Mishra, "Blowdown losses control in thermal power plants using neural network," *Int. J. Adv. Res. Technol.*, vol. 2, no. 5, pp. 10–13, 2013.
- [36] D. Strusnik and J. Avsec, "Artificial neural networking and fuzzy logic exergy controlling model of combined heat and power system in thermal power plant," *Energy*, vol. 80, no. 1, pp. 318–330, 2015.
- [37] S. T. Hashemi, O. M. Ebadati, and H. Kaur, "A hybrid conceptual cost estimating model using ANN and GA for power plant projects," *Nat. Comput. Appl.*, vol. 31, pp. 2143–2154, 2019.
- [38] C. A. Saleel, "Forecasting the energy output from a combined cycle thermal power plant using deep learning methods," *Case Stud. Therm. Eng.*, vol. 28, p. 101693, 2021.
- [39] S. Dutta and S. Ghosh, "Predicting electrical power output in a combined cycle power plant – a statistical approach," *Int. J. Energy Eng.*, vol. 11, no. 2, pp. 17–26, 2021.
- [40] P. Kaewprapha, P. Prempaneerachet, V. Singh, T. Tinikul, and N. Intarangsi, "Machine learning approaches for estimating the efficiency of combined cycle power plant," in *Proc. Int. Electr. Eng. Congr. (iEECON)*, Khon Kaen, Thailand, 2022, pp. 1–4.
- [41] A. Lakshmanarao, G. V. Kumar, and T. S. R. Kiran, "An effective multiple linear regression model for power load prediction," *J. Emerg. Technol. Innov. Res.*, vol. 5, no. 9, pp. 756–760, 2018.
- [42] M. S. S. Danish, Z. Nazari, and T. Senjyu, "AI-coherent data-driven forecasting model for a combined cycle power plant," *Energy Convers. Manag.*, vol. 286, p. 117063, 2023.
- [43] T. Danesh, R. Quaret, P. Floquet, and S. Negny, "Neural network sensitivity and interpretability predictions in power plant application," *Preprint, SSRN*, 2022. Available: <http://dx.doi.org/10.2139/ssrn.4119745>.
- [44] E. L. Ntantis and V. Xezonakis, "Optimization of electric power prediction of combined cycle power plant using innovative machine learning technique," *Optim. Control Appl. Methods*, vol. 45, no. 5, pp. 2218–2230, 2024.
- [45] M. K. Mohammed, O. I. Awad, M. M. Rahman, G. Najafi, F. Basrawi, A. N. Abd Alla, and R. Mamat, "The optimum performance of the combined cycle power plant: a comprehensive review," *Renew. Sustain. Energy Rev.*, vol. 79, pp. 459–474, 2017.
- [46] Y. Zhao and L. K. Foong, "Predicting electrical power output of combined cycle power plants using a novel artificial neural network by electrostatic discharge optimization," *Measurement*, vol. 198, p. 111405, 2022.
- [47] UCI Machine Learning Repository, "Combined Cycle Power Plant Data Set," 2012. Available: [+++https://archive.ics.uci.edu/ml/datasets/combined+cycle+power+plant](https://archive.ics.uci.edu/ml/datasets/combined+cycle+power+plant). [Accessed: 20-Jul-2023].
- [48] The MathWorks Inc., *MATLAB Version R2018b*. Natick, Massachusetts: The MathWorks Inc., 2018.
- [49] R. Siddiqui, H. Anwar, F. Ullah, R. Ullah, M. A. Rehman, N. Jan, and F. Zaman, "Power prediction of combined cycle power plant (CCPP) using machine learning algorithm-based paradigm," *Wirel. Commun. Mob. Comput.*, vol. 2021, p. 9966395, 2021.
- [50] X. Wang, X. Sun, S. Chu, J. Watada, and J. Pan, "Improved butterfly algorithm applied to prediction of combined cycle power plant," *Math. Comput. Simul.*, vol. 24, pp. 337–353, 2023.
- [51] B. A. Petrovic and S. M. Soltani, "Optimization of post-combustion CO₂ capture from a combined-cycle gas turbine power plant via Taguchi design of experiment," *Processes*, vol. 7, no. 6, p. 364, 2019.
- [52] M. Dirik, "Prediction of NO_x emissions from gas turbines of a combined cycle power plant using an ANFIS model optimized by GA," *Fuel*, vol. 321, p. 124037, 2022.
- [53] D. Saez, F. Milla, and L. Vargas, "Fuzzy predictive supervisory control based on genetic algorithms for gas turbines of combined cycle power plants," *IEEE Trans. Energy Convers.*, vol. 22, no. 3, pp. 689–696, 2007.
- [54] D. Saez and R. Zuniga, "Cluster optimization for Takagi & Sugeno fuzzy models and its application to a combined cycle power plant boiler," *Proc. 2004 Amer. Control Conf.*, vol. 2, pp. 1776–1781, 2004.
- [55] I. Lorencin, V. Mrzljak, and Z. Car, "Genetic algorithm approach to design of multi-layer perceptron for combined cycle power plant electrical power output estimation," *J. Energies*, vol. 12, no. 22, p. 4352, 2019.
- [56] P. Hundi and R. Shahsavari, "Comparative studies among machine learning models for performance estimation and health monitoring of thermal power plants," *J. Appl. Energy*, vol. 265, p. 114775, 2020.
- [57] Z. Qu, J. Xu, Z. Wang, R. Chi, and H. Liu, "Prediction of electricity generation from a combined cycle power plant based on a stacking ensemble and its hyperparameter optimization with a grid-search method," *J. Energy*, vol. 227, p. 120309, 2021.
- [58] M. Karaçor, A. Uysal, H. Mamur, G. Şen, M. Nil, M. Z. Bilgin, H. Doğan, and C. Şahin, "Life performance prediction of natural gas combined cycle power plant with intelligent algorithms," *J. Sustain. Energy Technol. Assess.*, vol. 47, p. 101398, 2021.